

# KENYON WILSON

PROFESSIONAL LAND SURVEYORS  
DEVELOPMENT CONSULTANTS

221 Coronation Avenue, Duncan, BC V9L 2T1 Phone: (250) 746-4745

Robin W. Kenyon, B.C.L.S., C.L.S.  
E.J. (Ed) Wilson, B.C.L.S., C.L.S., BSc (Eng'g)  
Allen L. Cox, B.C.L.S.  
David D. Symonds, B.C.L.S.  
Joe K. Kinrade, Tech. Mgr.

[www.kenyonwilson.ca](http://www.kenyonwilson.ca)

Cowichan Valley Regional District  
175 Ingram Street, Duncan, BC,  
V9L 1N8

May 3<sup>rd</sup>, 2023  
Our File # 09-6929

Attn: Gord Shewchuk, Building Inspector

**RE: Lot 3, Block H, Section 23, Renfrew District, Plan 1445.**


Dear Sir,

Kenyon Wilson has undertaken the survey to measure the Geodetic Elevation of the Underside of floor joists for the Dwelling located on Said Lot 3.

Elevations have been derived from B.C. Water Resources Monument # 728, with a published elevation of 166.497 metres.

We report that the underside of said floor joists have an elevation of 168.17 metres. Thus the underside of the floor joists are 0.84 metres above the 200 year flood plain (167.33 metres) for Cowichan Lake.

Yours Truly



Allen L. Cox BCLS