



ISLANDER

ENGINEERING

MEMORANDUM

Date: October 22, 2020

To: Bell Consulting Group

Project: 455

Attention: Dale Bellavance

RE: **"Cowichan Bay Campground"** – Lochmanetz Road (PID 024-681-814) – Lot 2 Section 10, Range 2, and District Lot 690 Cowichan District, Plan VIP70020

We can confirm that the above captioned site has been excavated to a suitable bearing subgrade for the intended use/purpose. We can also confirm that a geotextile fabric was placed on the approved subgrade surface prior to the placement and compaction of suitable well graded aggregate. We have no concerns with respect to the geotechnical procedures completed to date, and when site servicing commences, we will ensure that proper testing of all materials will be completed in accordance with MMCD and good engineering practices.

If you require any further information in this regard, please do not hesitate to contact the undersigned.

Yours Truly,

ISLANDER ENGINEERING LTD.



 Mike Achtem, P.Eng, PMP, CGA
 Principal, Managing Director